



ENVIRONMENTAL CLAIM VALIDATION SUMMARY

FILT AIR LTD

Sterionizer D5 Series

Report Number:

252670-4180

Validation Period:

26 Oct 2021 - 26 Oct 2023

Claim:

Zero Ozone Emissions – Measured Ozone Emissions from Sterionizer™ D5 Series during use phase does not exceed 0.005 ppm as tested by UL 867.

Method:

ECVP 2998 Zero Ozone Emissions from Air Cleaners, Third Edition - 2020

Facility:

Filt Air Ltd.