



ENVIRONMENTAL CLAIM VALIDATION SUMMARY

FILT AIR LTD

Sterionizer D6 Duct Unit

Report Number:

260727-4180

Validation Period:

11 Apr 2022 - 14 Dec 2023

Claim:

Zero Ozone Emissions – Measured Ozone Emissions from Sterionizer™ D6 Series during use phase does not exceed 0.005 ppm as tested by UL 867.

Method:

ECVP 2998 Zero Ozone Emissions from Air Cleaners, Third Edition - 2020

Facility:

Filt Air Ltd.