



# ENVIRONMENTAL CLAIM VALIDATION SUMMARY

## FILT AIR LTD

### Sterionizer D6 Series

**Report Number:**

187806-4180

**Validation Period:**

14 Dec 2020 - 14 Dec 2023

---

**Claim:**

Zero Ozone Emissions – Measured Ozone Emissions from PlasmaPURE AutoClean 1500 during use phase does not exceed 0.005 ppm as tested by UL 867.

**Method:**

ECVP 2998 Zero Ozone Emissions from Air Cleaners, Third Edition - 2020

**Facility:**

Filt Air Ltd.